





## MATERIAL SPECIFICATION

VOCAB NUMBER	ITEM DESCRIPTION		
132127	STAYWIRE, GALVANISED STEEL, 19/2.75 (SC/GZ)		
SPECIFICATION DETAILS			
<p>Galvanised steel staywire in accordance with AS 1222, Part 1 – 1992 size 19/2.75 (SC/GZ).</p> <p>Test Certificate shall be provided as required in the Standard.</p> <p>The staywire shall be supplied in coils of 100m length.</p> <p>Technical information shall be included with the tender.</p>			
<ul style="list-style-type: none"><li>• <b>Unit of Measure:</b> Each</li><li>• <b>Rejection:</b> PNG Power Ltd reserves all rights to reject whole or part of the order not complying with this specification and is not liable for any cost or loss with the return of rejects to the Supplier. Facilitation of Invoice Credit must commence between the supplier and PNG Power Ltd through the process of PNG Power Ltd Discrepancy Report provisions.</li></ul>			
<b>Drawing References:</b>		<b>Manufacturer's Product Code:</b>	
<b>STANDARDS COMMITTEE APPROVAL</b>			
Approval by Alex Oa Chairman		Signature: 	Date: 22/8/16
<b>DATA REVIEW ENDORSEMENT</b>			
NAME	TITLE	SIGNATURE	DATE
Grevasias Peni	Team Leader Standards and Material		22/8/16
	//		04/03/20